



Declaration of Conformity

Directive: PED 97/23/EC

Notice Date: 01/05/02

Manufacturer:

Sporlan Valve Company
206 Lange Dr.
Washington, Missouri 63090 USA

EU Community Authorized Representative:

ACAL Controls Ltd.
Unit 2, The Rose Estate
Osborn Way
Hook Hampshire
RG27 9UT
Phone: 44-1256-382520
Fax: 44-1256-382530

Declaration:

The following Moisture Liquid Indicator products conform to the requirements of the Pressure Equipment Directive PED 97/23/EC as:

Type of Equipment: Pressure Accessories

Fluid Group: Group 2 – Gas (HFC & HCFC refrigerants from group L1 of prEN 378-1)

Maximum Allowable Pressure: PS = 44.8 bar (650 psig)

Connections: DN < 32 mm (1.25 inches)


Category: Sound Engineering Practice – SEP or a3p3

Products do not bear the CE mark


Moisture Liquid Indicator Models when Supplied with

Connections < 32 mm:

SA-12(S), SA-13(S), SA-14(S), SA-15(S), SA-17S, SA-19S,
SA-K, AC-20 Series



Michael Lacey
Product Design Manager
Sporlan Valve Company



Angus Mackintosh
General Manager
ACAL Controls Ltd.