



# Declaration of Conformity

**Directive:** PED 97/23/EC

**Notice Date:** 01/05/02

**Manufacturer:**

Sporlan Valve Company  
206 Lange Dr.  
Washington, Missouri 63090 USA

**EU Community Authorized Representative:**

ACAL Controls Ltd.  
Unit 2, The Rose Estate  
Osborn Way  
Hook Hampshire  
RG27 9UT  
Phone: 44-1256-382520  
Fax: 44-1256-382530

**Declaration:**

The following Moisture Liquid Indicator products conform to the requirements of the Pressure Equipment Directive PED 97/23/EC as:

**Type of Equipment:** Pressure Accessories

**Fluid Group:** Group 2 – Gas (HFC & HCFC refrigerants from group L1 of prEN 378-1)

**Maximum Allowable Pressure:** PS = 44.8 bar<sub>g</sub> (650 psig)

**Connections:** DN < 100 mm (3.9 inches)

**Category:** Category I, Module A

**Moisture Liquid Indicator Models:**

SA-211, SA-213, SA-217

Michael Lacey  
Product Design Manager  
Sporlan Valve Company

Angus Mackintosh  
General Manager  
ACAL Controls Ltd.