



A Unit of Cambridge-Lee Industries, Inc.

P.O. Box 14026 • Reading, PA USA 19612-4026 • Phone: (610) 926-4141 • FAX: (610) 923-7817

Distributor	: IBERICA DE SUM, Y EXCLUSIVAS, SA Contractor	P. O. No	:
Address	: MARIA AUXILIADORA, 7 08017 BARCELONA	Product	: SEAMLESS DHP COPPER TUBE, ACR, ASTM B280 IN 20' LENGTHS COPPER UNS C122: 99.9%, PHOSPHOROUS: 0.015-0.040%

Certificate Of Conformance

I certify that all copper tubing manufactured by Reading Tube Corporation meets the applicable requirements of the specification(s) indicated below. In addition, all copper tubing conforms to the chemical requirements for Copper Alloy UNS No. C12200 and is 100% eddy current tested in diameters up to 3.125". Copper tube manufactured by Reading Tube does not contain mercury or come in contact with mercury, mercury compounds or mercury containing devices at any stage in manufacturing, inspection, packaging or shipping.

- ASTM B 88 Standard Specification for Seamless Copper Water Tube
- ASTM B 280 Standard Specification for Seamless Copper Tube for Air Conditioning and Refrigeration Field Service
- ASTM B 306 Standard Specification for Copper Drainage Tube (DWV)
- ASTM B 819 Standard Specification for Seamless Copper Tube for Medical Gas Systems
- NFPA 99 C Standard for Health Care Facilities
- CGA G-4.1 Cleaning Equipment for Oxygen Services

Bradley S. Schroeder
Director of Quality and Engineering

3/20/97

Date